

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:55 pm

PWS ID: UTAH25109 **Name:** NORTH FORK SSD

Legal Contact NORTH FORK SSDXX

DAVID J BOSHARD

Address: RR3 PO BOX B1 SUNDANCE
PROVO, UT 84604

Phone Number:

City Served (Area):

County: UTAH COUNTY

System Type: Community

Activity Status Cd: Active

Population: 1,500

Last Inv Update: 05/05/2011

Last Snty Srv Dt: 10/26/2009

Surveyor: LANTY ROSS

Oper Period: 1/1 to 12/31

Rating: Approved

Rating Date: 05/05/1988

Activity Status: Active

Gal/Day Gal/Min

Avg Daily Prod:

Total Dsgn Cap:

Total Emerg Cap:

Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	BOSHARD, DAVID J		801-226-6159		dave@nfsd.org

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	310
			310 Total Svc Connections

Storage

Total Storage: 600,000 GAL

Number of Units: 3

Adequate Capacity: NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STEWART SPRING TANK	Ground	50,000 GAL	Concrete		A	
ST002	ASPEN GROVE TANK	Ground	150,000 GAL	Concrete		A	NO
ST003	400000 GALLON TANK	Ground	400,000 GAL	Concrete		A	

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	ASPEN GROVE CHLORINATOR		A	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	ASPEN GROVE BOOSTER	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	ASPEN GROVE SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	STEWART CASCADE SPRIN	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS003	TIMPANOGAS SPRING	Active	SP				Yes	GU	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*